

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/School/NDZ/2021/ 319

Dated: 13/04/2021

FIRE SAFETY CERTIFICATE

Certified that the **Kerala Education Society Regd. Senior Secondary School** located at **Srimat Madhav Rao, Scindia Marg, (Canning Road), New Delhi** comprises of **Ground + 02 Upper floor** was granted FSC by this department vide letter No. **F6/DFS/MS/School/2017/1110 dated 27/07/2017**. The premises was re-inspected by the officer concerned of this department on 01-04-2021 in the presence of Sh. Hari Kumar. K.G (Prinacpal) and found that the said school building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of class **Group B "Educational Building" Sub-Div. B-I** with effect from 13/04/2021 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 on the conditions printed below.

Issued on ...13/04/2021..... at New Delhi by.


814111

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Principal,
Kerala Education Society Regd. Senior Secondary School,
Srimat Madhav Rao Scindia Marg, (Canning Road), New Delhi.
2. Director of Education,
Old Secretariat, Govt. of NCT, Delhi - 54.

Condition for the validity of fire safety certificate

1. All the means of escape shall be kept free of all types of obstruction all the time.
2. All the fire safety arrangements provided there in shall be maintained in good working condition at all time.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Basement shall be used as per NBC/BBL 1983.
6. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
7. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry".